

COUNCIL MEETING AGENDA

ADDENDUM

May 10, 2022

**Chris Riggs, Mayor**  
**James "Bud" Turner, Vice-Mayor**

**Jennifer Franks**  
**Clyde Kreegerr**  
**Will Sipes**

**Tommy Lee Sikes**  
**Fernando Fernandez**

Gila Bend Unified School District  
Media Center  
308 N Martin Ave.  
Gila Bend, Arizona

Regular Meeting  
6:00 PM

**THE ITEM MAY BE DISCUSSED EARLIER OR IN A DIFFERENT SEQUENCE**

AGENDA ADDEDUM ITEM

**Papago Street Sewer Reconstruction Project Change Order #3:** The Mayor and Town Council may discuss and possibly take action to approve contract Change Order #3 related to the Papago Street Sewer Reconstruction Project.

**Discussion and Action**

REASONABLE ACCOMMODATIONS FOR PERSONS WITH DISABILITIES AND PERSONS WITH LIMITED ENGLISH PROFICIENCY WILL BE PROVIDED UPON REQUEST. PLEASE TELEPHONE YOUR ACCOMMODATION REQUEST (928 683-2255 OR 1-800-367-8939 ADD ARIZONA RELAY SERVICE) 72 HOURS IN ADVANCE IF YOU NEED A SIGN LANGUAGE INTERPRETER OR ALTERNATE MATERIALS FOR A VISUAL OR HEARING IMPAIRMENT; FOR AN ENGLISH TRANSLATOR CALL 928 683-2255.

LOS ALOJAMIENTOS RAZONABLES PARA PERSONAS CON INCAPACITATES Y PERSONAS CON LA PERICIA INGLESA LIMITADA SERAN PROPORCIONADOS SOBRE EL PEDIDO. TELEFONEE POR FAVOR SU PEDIDO DEL ALOJAMIENTO (928 683-2255 O 1-800-367-8939 AGREGAN ARIZONA EL SERVICIO DEL RELEVO) 72 HORAS EN EL AVANCE SI USTED NECESITA A UN INTERPRETE DE LENGUAJE POR SEÑAS O ALTERNA LAS MATERIAS PARA UN VISUAL O DETERIORO DE VISTA; PARA UNA LLAMADA INGLESA DE TRADUCTOR 928 683-2255.

Posted 05/06/2022

Time: Before 12:00 pm



## STAFF REPORT

TO: Mayor Riggs and Town Council  
FROM: Katherine Valenzuela  
SUBJECT: Change Order #3 for Papago Street Sewer Repair  
DATE: 5.10.22

---

### Agenda Item:

Change Order #3 for Papago Street Sewer Repair. The Mayor and Town Council shall discuss and possibly take action to approve change order #3 for Papago Street Sewer Repair.

### Background:

The Town of Gila Bend sustained damage to the Papago Street sewer line across two washes as a result of the flood event on August 13-14, 2021.

The Maricopa County Board of Supervisors awarded the Town funds to help with flood damage. Eligible activities must align with the federal funds Maricopa County will be using to help the Town.

Geotechnical analysis and engineering design has been provided by the Contractor regarding the location and depth of new piers to support the new sewer pipe at the two wash locations on this project. As a result, 30-foot embedded micro piles are recommended for each support, with one (1) pier support located under each section of new pipe, spacing the new piles 18 feet apart.

An 18-foot spacing will require seven (7) new supports in Sand Tank Wash (west) and six (6) new supports in Bender Wash (east). The 13 pier supports that are recommended increases the bid quantity by 3 additional supports. Based on the Contractor's unit price for pier supports, the cost will increase by \$46,885.02.

Dick Wallace, Town Engineer, concurs with this recommendation.

### Recommendation:

Staff would like to recommend for the Mayor and Town Council to possibly take action to approve change order #3 for Papago Street Sewer Repair.